

9713106858
8770736154

Reg. No. /S/220452
GSTIN : 23ARFPT9401N1ZE

SA² ENTERPRISES

Add : 50, Cantt, Mall Road, Opp. S. P. Bunglow, SAGAR - 470001 (M.P.)



TEST & WARRANTY CERTIFICATE

Date 15/2/2021

No. 034

Party Name Kendriya Vidyalaya No.-3

Address RTO Road, Sagar (M.P.)

Item & Quantity of Fire Extinguisher's

	Kg.	Qty.	Refiling From	To
1. Water / MF Type				
2. DCP				
3. CO ²	4.5Kg, 2.5Kg	(10), (2)	15/2/2021	15/2/2022
4. Modular Type Clean Agent				
5. ABC	6Kg	(14)	15/2/2021	15/2/2022
6. M.F.				

Hydraulic Pressure Test Yes Tested On 35 Bar

Age of Fire Ex. N/A Validity One year

Body Warranty NO

Remarks Refilled and ready to use.



SA² ENTERPRISES
PROPRIETOR
Auth. Signature
SA² ENTERPRISES